



# CERTIFICATE

Issued to:  
Applicant:  
**Santon International B.V.**  
**Hekendorpstraat 69**  
**3079 DX Rotterdam, The Netherlands**

Manufacturer/Licensee:  
**Santon International B.V.**  
**Hekendorpstraat 69**  
**3079 DX Rotterdam, The Netherlands**

Product(s) : rotary switch-disconnector  
Trade name(s) : SANTON  
Type(s)/model(s) : XA100.25R8-(B)

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-3:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 901095

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 19 June 2012 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2153598.01

DEKRA Certification B.V.

drs. G.J. Zoetbrood  
Managing Director

F.S. Strikwerda  
Certification Manager

© Integral publication of this certificate is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

ACCREDITED BY  
THE DUTCH COUNCIL  
FOR ACCREDITATION



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product	:	rotary switch-disconnector
trade name(s)	:	SANTON
type(s)	:	XA100.25R8-(B)
rated insulation voltage (Ui)	:	1000 V
conventional free air thermal current (Ith)	:	25 A
ratings/utilization category (Ue-Ie)	:	<u>DC-21B</u> 1000 V 25 A
rated short-time withstand current (Icw)	:	700 A - 1 s
rated short-circuit making capacity (Icm)	:	1400 A
rated impulse withstand voltage (Uimp)	:	8 kV
operational performance without current	:	category B 1700 operating cycles
with current	:	300 operating cycles
connection capacity	:	1 mm <sup>2</sup> - 6 mm <sup>2</sup> flexible
method of operation	:	independent operation, rotary,
number of position of contacts	:	4 positions (0°, 90°, 180°, 360°)
number of poles/type of contact	:	maximum 12 poles, 1 single pole contact per pole
contact composition	:	min 2 contacts in + pole and 1 contact in - pole
degree of protection	:	IP20 or IP66 when mounted in an enclosure of ≥IP 66 with gland of the shaft for panel mounting
For use in ambient temperatures	:	-40 °C to 70°C

**TESTS****Test requirements**

EN 60947-3:2009

**Test result**

The test results are laid down in DEKRA test file 2153598.01.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : M.T. H. van Gemen

Checked by : H.L. Schendstok



**Factory locations**

Santon Holland B.V.  
Berkenwoudestraat 4-6, 3079 JA, Rotterdam  
The Netherlands